



NOTES

1. When distance from hydrant to the top or toe of slope is less than 2 feet special installation will be required by district.
2. Where hydrant is not protected by a vertical face of curb protective posts are required.
3. The centerline of the hydrant shall be located 5' minimum from curb return and minimum 5' from driveway or any fixed obstruction.

NOT TO SCALE

	<p>East Greenacres Irrigation District</p>	<p>Approved by:</p>
	<p>Fire Hydrant Locations</p>	<p><i>Ron Wilson</i> District Manager</p>
		<p>5/19/15 Date</p>
		<p>Standard Drawing No. W-3</p>