



ITEM NO.		NO. REQ'D.		APPROVED TAPPING METHOD AND PARTS	
				DESCRIPTION	
1	1			ROMAC DOUBLE STRAP SERVICE SADDLE	
2	1			IPS x POLY PACK JOINT BRONZE CORPORATION STOP.	
3	1			1", 1 1/2", 2" x POLY REQ. LENGTH - USE PIPE SIZE, 250 PSI POLYETHYLENE SERVICE LINE	
4	1			IPS x POLY BRASS PACK JOINT ADAPTER	
5	1			MIN 10' LONG - GALVANIZED IRON PIPE BACK SIDE	
6	1			GALVANIZED CAP.	
7	1			* APPROVED NO LEAD COPPERSETTER, FORD 1" VBHC74-36W-11-44-NL   A.Y. McDONALD 1" 720-436WDDDD44 FORD 1 1/2" VBH76-36-11-66   A.Y. McDONALD 1 1/2" 720-B636WDF665 FORD 2" VBH77-36-11-77   A.Y. McDONALD 2" 720-B736WDF775	
8	2			POLY INSERTS WHERE NEEDED	
9	1			MASTER RADIO READ METER - SEE WATER SYSTEM NOTES #21 METER LENGTH: 1" = 11" 1 1/2" = 13" 2" = 17"	
10	4			1" 17x28x12 ARMORCAST BOX #A6001419, 1 1/2" AND 2" 17x30x12 A6001640PCX12	

**NOTES:**

- ALL BRASS MATERIALS USED IN CONTACT WITH POTABLE WATER ARE TO BE NO LEAD.
- STABILIZER BAR MUST BE USED FOR SETTINGS HAVING POLY PIPE ON BOTH FRONT AND BACK SIDES.
- \*\* NO PRIVATE CONNECTIONS OR FITTINGS ALLOWED INSIDE THE METER BOX\*\*.
- POLY PIPE MAY BE USED WHEN CONNECTING TO AN EXISTING SERVICE WHEN A GALVANIZED CONNECTION CANNOT BE EASILY MADE.
- \* COMMERCIAL APPLICATIONS ADD (B) AFTER 36 FOR A COPPERSETTER BYPASS.

**NOT TO SCALE**



East Greenacres Irrigation District

1", 1 1/2", 2" Coppersetter  
Standard Pit Settings

Approved by:

*R. White*  
District Manager

2/01/18  
Date

Standard Drawing No.  
**W-1**